

Kitemark™ Certificate

This is to certify that:

Smartwares Europe
Jules Verneweg 87
Tilburg
5015 BH
The Netherlands

Holds Certificate Number:

KM 724152

In respect of:

BS EN 3
Portable fire extinguishers

This issues the right and licence to use the Kitemark in accordance with the Kitemark Terms and Conditions governing the use of the Kitemark, as may be updated from time to time by BSI Assurance UK Ltd (the "Conditions"). All defined terms in this Certificate shall have the same meaning as in the Conditions.

The use of the Kitemark is authorized in respect of the Product(s) detailed on this Certificate provided at or from the above address.

For and on behalf of BSI:

Chris Lewis - Certification Director, Product Certification

First Issued: 2020-06-12

Effective Date: 2020-06-12

Latest Issue: 2020-06-12

Expiry Date: 2023-06-11

Page: 1 of 2



003

...making excellence a habit.™

Kitemark™ Certificate

No. KM 724152

Model No	Description	Branded As
BB1.4	1 kg 30% ABC powder, stored pressure. Fire rating 8A & 34B	Smartwares
BB2.4	2 kg 30% ABC powder, stored pressure. Fire rating 13A & 70B	Smartwares
BB3.4	3 kg 30% ABC powder, stored pressure. Fire rating 21A & 89B	Smartwares
BB4.4	4 kg 30% ABC powder, stored pressure. Fire rating 27A & 113B	Smartwares
BB6.4	6 kg 30% ABC powder, stored pressure. Fire rating 43A & 233B	Smartwares
SB2.4	2 litre foam (3% AFFF), stored pressure. Fire rating 8A & 55B	Smartwares
SB3.4	3 litre foam (3% AFFF), stored pressure. Fire rating 13A & 70B	Smartwares
SB6.4	6 litre foam (3% AFFF), stored pressure. Fire rating 21A & 144B	Smartwares
SB9.4	9 litre foam (3% AFFF), stored pressure. Fire rating 27A & 183B	Smartwares
VB2	2 litre wet chemical, stored pressure. Fire rating 8A & 40F	Smartwares
VB6	6 litre wet chemical, stored pressure. Fire rating 13A & 75F	Smartwares
CB2	2 kg carbon dioxide, steel body, fixed horn. Fire rating 34B	Smartwares
PE1	1 kg 30% ABC powder, stored pressure. Fire rating 8A & 34B	Byron
PE2	2 kg 30% ABC powder, stored pressure. Fire rating 13A & 70B	Byron
PE3	3 kg 30% ABC powder, stored pressure. Fire rating 21A & 89B	Byron
PE4	4 kg 30% ABC powder, stored pressure. Fire rating 27A & 113B	Byron
PE6	6 kg 30% ABC powder, stored pressure. Fire rating 43A & 233B	Byron
FE2	2 litre foam (3% AFFF), stored pressure. Fire rating 8A & 55B	Byron
FE3	3 litre foam (3% AFFF), stored pressure. Fire rating 13A & 70B	Byron
FE6	6 litre foam (3% AFFF), stored pressure. Fire rating 21A & 144B	Byron
FE9	9 litre foam (3% AFFF), stored pressure. Fire rating 27A & 183B	Byron
GE2	2 litre wet chemical, stored pressure. Fire rating 8A & 40F	Byron
GE6	6 litre wet chemical, stored pressure. Fire rating 13A & 75F	Byron
CE2	2 kg carbon dioxide, steel body, fixed horn. Fire rating 34B	Byron

All the above products are certified to BS EN 3-7:2004+A1:2007

First Issued: 2020-06-12

Effective Date: 2020-06-12

Latest Issue: 2020-06-12

Expiry Date: 2023-06-11

Page: 2 of 2

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.